## **Summary of Qualification for TEC-156 Analog Signal Isolators**

(prepared November 2011)

Isolation Integrity (type tested):

Output (non-IE) faults without significant impact to input (IE) side:

(as reported in 156-TR-02 R2)

short - output to common

supply to common

supply and output to common

open - supply

output common

output and common supply and common supply and output

supply, output and common

120 Vac @ 20A\* - output to common

supply to common

(as reported in 156-TR-03 R1)

2000 Vdc @ 20ma - output to common

Common-mode input side fault without significant deviation at output side:

(as reported in 156-TR-02 R2)

2000 Vdc applied to input and common terminals

## Aging:

Equivalent to 20 years @ 135 °F plus 100 days @ 146 °F (Activation Energy 0.86 eV) (as reported in 156-TR-04 R2)

## Radiation:

Equivalent to 880 R operational exposure of 40 years plus 11,000 R accident exposure (as reported in 156-TR-04 R2)


## Seismic:

Two separate RRS curves applied on two separate test sequences. (as reported in 157-TR-01 R0 and 156-TR-04 R2)

Tested to IEEE standards 323-1974, 323-1983, 344-1975, 344-1987, 381-1977, 384-1981, 472-1974

<sup>\*</sup> Expected and observed destruction of some components on non-IE side but isolation integrity was maintained

Safe Shutdown Earthquake (SSE)
Horizontal Acceleration
Vertical Acceleration is 2/3
of Horizontal Acceleration
Operating Basis Earthquake = 1/2 SSE



Frequency (Hertz)

Figure 1. Required Response Spectra (RRS) for 2% of Critical Damping

1111

TABLE LIMIT

Report No. S945-RP-01

Page 113 Revision 0

SOUTHERN TESTING SERVICES, INC. (STS)

TITLE: SEISMIC TEST PROCEDURE FOR TECHNOLOGY FOR ENERGY CORPORATION MODEL 1.56

ANALOG SINGLE CHANNEL ISOLATORS

PROCEDURE NO. S945-TP-03

REVISION NO. 2 PAGE 6 OF 16

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 🗆 10 🖾 100 🕅 1000🖂

DAMPING 2%




FIGURE 5.2 SAFE SHUIDOWN EARTHQUAKE (SSE)
REQUIRED RESPONSE SPECTRA
(HORIZONTAL AND VERTICAL)